

Maharashtra State Public Health Services,
District Public Health Laboratory, Ahmednagar
Old Civil Hospital compound, Chitale road, Ahmednagar 414 001
Ph.No.0241/2354038

Report of Bacteriological Examination of Water Sample

Sender's Name & Address :- *Principal, MIRC Primary School, Ahmednagar*

Letter No. & date :- Date **21** /06/2023

Lab. Ref. No. :- 54 /385

Date of sample collection : 21 / 06/2023

Date of receipt of sample : 21 / 06/2023

Date of analysis : 21 / 06/2023

| Sr. No. | Particulars of sample | Results of analysis | | | Remark |
|---------|--|--|-------------------------|--------|----------------------------|
| | | Bacterial count per 100 ml of water sample | | | |
| | | Coliforms | Thermotolerant bacteria | E.coli | |
| 1 | MIRC School Water (RO) Provided by Municipal Corpo.A.Nagar | 00 | -- | -- | Fit for drinking (Potable) |

Note : 1. Above sample is not collected by this office, but submitted by concerned authority.

2. Results are as per sample submitted to laboratory and it assumed that it's the representative sample of whole stock.

Remark : The said water can be used for drinking purpose only after proper chlorination and ascertaining it's bacteriological quality.

Report No. | *113*

Date-*27* / 06 / 2023

To,

Principal, MIRC Primary School, Ahmednagar


Junior Scientific Officer
District Public Health Laboratory
Ahmednagar